

	N° Page
Resume of the Wind Farm	1
Bilan of the availability	2
Statistics of the Active power production	3
Power Curve	4
Status List	5
Comments	6

Report established by
The Turbine Management
Nordex France SAS

Customer : Endesa France
Name : Burlot
First Name : Franck
Address : 2, rue Jacques Daguerre
Code postal: F-92565
City : Reuil Malmaison Cedex
Phone : 01 47 52 40 01
Fax : 01 47 52 39 29
Email : franck.burlot@snet-electricite.fr

Operating company : NORDEX FRANCE SAS
Name : Jarrot
First Name : Damien
Address : 1, rue de la procession
Code postal: F-93217
City : La plaine St Denis
Phone : 01 49 46 66 93
Fax : 01 55 93 43 40
Email : DJarrot@nordex-online.com



Wind Farm :	Lehaucourt	
Operating Company :	Nordex France	
Starting date for the availability :	01/04/2007	
Type of Turbine :	N90 R80 LS	
Number of the turbine :	4	
Power of the turbine :	2500	Kw
Power of the Wind Farm :	10000	Kw

Monthly report for the June 2007**Data Keys from the NC2:**

Availability of the Windfarm for the June 2007	97,59 %
Availability of the Windfarm since the 01/04/07	87,13 %
Active power production of the Windfarm to the 30/06/07	4 103 812 Kwh
Average production by turbines to the 30/06/07	1 025 953 Kwh

Stop Times Tstop AF June 2007	69:24:16	h
Stop Times Tstop NAF June 2007	1:24:35	h
Total Stop Time :	70:48:51	h

Comments:

Exchange gearoil filter on the 8386.

Nordex France SAS



Wind Farm

Customer :


Endesa France

Lehaucourt

Availability by Turbines - Monthly 2007/2008



	Apr 2007	May 2007	June 2007	July 2007	Aug 2007	Sept 2007	Oct 2007	Nov 2007	Dec 2007	Jan 2008	Feb 2008	Mar 2008
1 WEA 8383	60,32%	97,38%	99,99%									
2 WEA 8384	47,36%	93,79%	99,85%									
3 WEA 8385	80,71%	94,60%	96,93%									
4 WEA 8386	89,62%	90,45%	93,60%									
Farm	69,50%	94,05%	97,59%									



Wind Farm
Lehaucourt


Cust : **Endesa France**
Period : **Year of Expl. 2007/2008 - Farm Availability**



Annual availability
Farm 2007/2008

Apr 2007 69,50% May 2007 94,05% June 2007 97,59% July 2007 Aug 2007 Sept 2007 Oct 2007 Nov 2007 Dec 2007 Jan 2008 Feb 2008 Mar 2008

87,13%



Wind Farm
Lehaucourt

Customer
Period :

Endesa France
Year of Exploitation 2007/2008

Annual Statistics - Availabilities




April 2007					
WTG	Stop Times (AF) I _m	Stop Times (NAF)	Operating hours numbers M _m	Availability by turbines (Awtg)	Availability of the Farm by month
1 WEA 8383	285,67	35,26	720,00	60,32%	
2 WEA 8384	379,04	34,51	720,00	47,36%	
3 WEA 8385	138,90	43,47	720,00	80,71%	
4 WEA 8386	74,71	42,53	720,00	89,62%	69,50%
May 2007					
1 WEA 8383	19,52	76,94	744,00	97,38%	
2 WEA 8384	46,17	77,53	744,00	93,79%	
3 WEA 8385	40,19	78,38	744,00	94,60%	
4 WEA 8386	71,08	77,48	744,00	90,45%	94,05%
June 2007					
1 WEA 8383	0,10	0,42	720,00	99,99%	
2 WEA 8384	1,10	0,24	720,00	99,85%	
3 WEA 8385	22,10	0,67	720,00	96,93%	
4 WEA 8386	46,10	0,09	720,00	93,60%	97,59%

Wind Farm : Lehaucourt
 Customer : Endesa France
 Period : Year of Exploitation 2007/2008

Annual Statistics - Availabilities 2007/2008

Annual Estimates

					Wind Farm
WTG	I _m	NAF	M _m	Rate : until the 30.06.2007	87,12568%
1 WEA 8383	305,29	112,61	2184,00	86,02%	
2 WEA 8384	426,32	112,28	2184,00	80,48%	
3 WEA 8385	201,19	122,52	2184,00	90,79%	
4 WEA 8386	191,90	120,10	2184,00	91,21%	
Sum :	1124,70	467,51	8736,00		




Wind Farm: Lehaucourt

Customer : Endesa France

Year of Exploitation 2007/2008 - Production (kWh) WTG / Months



	Apr 07	May 07	June 07	July 07	Aug 07	Sept 07	Oct 07	Nov 07	Dec 07	Jan 08	Feb 08	Mar 08	Year 2007/2008
1 WEA 8383	186 033	536 318	358 519										1 080 870
2 WEA 8384	132 797	536 533	350 109										1 019 439
3 WEA 8385	294 771	482 323	301 776										1 078 870
4 WEA 8386	232 308	400 945	291 380										924 633
Farm	845 909	1 956 119	1 301 784										4 103 812



**Wind Farm
Lehaucourt**

Customer :

Endesa France

Month :

June 07

Statistics of the production

	Amount [kWh]	Estimate of the amount H.T. [€]	Estimate of the amount (with TVA)
Total Monthly Production of the Farm from the SCADA :	1 301 784	106 746,29 €	127 668,56 €
Cumulated Production of the Farm from the SCADA since the 01.04.2007 :	4 103 812	336 512,58 €	402 469,05 €
Total Production WindFarm from the SCADA cumulated since the erection :	1 191 000 4 748 429	23 820,00 € 389 371,18 €	28 488,72 € 465 687,93 €
Invoice of the EDF Gross Power supply	1 275 740	104 610,68 €	125 114,37 €
Data deviations WTGs - EDF [%]	2,041	Gross Power supply kWh from the EDF cumulated since the 01.04.2007	4 032 877,00 kWh

WTG	Monthly Production SCADA [kWh]	Production SCADA [kWh] since the 01.04.2007	Production SCADA [kWh] since the Erection
1 WEA 8383	358 519	1 080 870	1 393 750
2 WEA 8384	350 109	1 019 439	1 525 288
3 WEA 8385	301 776	1 078 870	1 573 482
4 WEA 8386	291 380	924 633	1 446 909
sum :	1 301 784	4 103 812	5 939 429


Comments :

Average Production per WTG
(From SCADA)

325 446

Power Curve

Wind Farm : Lehaucourt



Wind Farm :
Lehaucourt

Customer :

Endesa France

Period :

June 2007



Status List

Status List		beginning : end :				h / min / s		Prevent Maintenance					
WTG	date	hours	hours	code	error	actions/comments	AF/NAF	duration	Tstop/AF/ L _h	T stop/NAF T _{fm}	T stop/NAF grid	T Im	
1 WEA 8383	06-juin-07	11:39:04	06/06/2007 11:39:25	FM411	Wind DirSlanting Stop		AF	00:00:21	00:00:21				
	07-juin-07	20:43:55	07/06/2007 20:44:28	FM332	LV Griderror 660V Alarm		GE	00:00:33			00:00:33		
	07-juin-07	20:44:28	07/06/2007 20:44:32	FM8	WTG AutoRestart after GridError		NAF	00:00:04		00:00:04			
	08-juin-07	10:12:48	08/06/2007 10:13:19	FM332	LV Griderror 660V Alarm		GE	00:00:31			00:00:31		
	08-juin-07	10:13:19	08/06/2007 10:13:24	FM8	WTG AutoRestart after GridError		NAF	00:00:05		00:00:05			
	09-juin-07	03:45:29	09/06/2007 03:46:01	FM332	LV Griderror 660V Alarm		GE	00:00:32			00:00:32		
	09-juin-07	03:46:01	09/06/2007 03:46:06	FM8	WTG AutoRestart after GridError		NAF	00:00:05		00:00:05			
	16-juin-07	12:34:07	16/06/2007 12:34:44	FM411	Wind DirSlanting Stop		AF	00:00:37	00:00:37				
	19-juin-07	20:19:27	19/06/2007 20:20:15	FM411	Wind DirSlanting Stop		AF	00:00:48	00:00:48				
	19-juin-07	20:34:38	19/06/2007 20:37:39	FM411	Wind DirSlanting Stop		AF	00:03:01	00:03:01				
	19-juin-07	20:39:16	19/06/2007 21:02:27	FM1003	Yaw CableRewind		NAF	00:23:11		00:23:11			
	20-juin-07	09:19:26	20/06/2007 09:20:02	FM411	Wind DirSlanting Stop		AF	00:00:36	00:00:36				
	25-juin-07	14:37:19	25/06/2007 14:37:31	FM411	Wind DirSlanting Stop		AF	00:00:12	00:00:12				
	25-juin-07	14:42:18	25/06/2007 14:42:46	FM411	Wind DirSlanting Stop		AF	00:00:28	00:00:28				
								0,52					
								00:06:03	00:23:25	00:01:36	00:00:00	Im Total 00:06:03	NAF Total 00:25:01
								0,10	0,39	0,03	0,00	0,10	0,42
2 WEA 8384	04-juin-07	13:41:52	04/06/2007 13:42:33	FM411	Wind DirSlanting Stop		AF	00:00:41	00:00:41				
	05-juin-07	08:55:44	05/06/2007 08:56:15	FM411	Wind DirSlanting Stop		AF	00:00:31	00:00:31				
	06-juin-07	13:13:01	06/06/2007 13:13:15	FM411	Wind DirSlanting Stop		AF	00:00:14	00:00:14				
	06-juin-07	15:14:52	06/06/2007 15:15:20	FM411	Wind DirSlanting Stop		AF	00:00:28	00:00:28				
	07-juin-07	20:43:55	07/06/2007 20:44:27	FM332	LV Griderror 660V Alarm		GE	00:00:32			00:00:32		
	07-juin-07	20:44:27	07/06/2007 20:44:32	FM8	WTG AutoRestart after GridError		NAF	00:00:05		00:00:05			
	07-juin-07	22:51:24	07/06/2007 22:51:58	FM332	LV Griderror 660V Alarm		GE	00:00:31			00:00:31		
	07-juin-07	22:51:55	07/06/2007 22:52:00	FM8	WTG AutoRestart after GridError		NAF	00:00:05		00:00:05			
	08-juin-07	01:08:41	08/06/2007 01:09:12	FM332	LV Griderror 660V Alarm		GE	00:00:31			00:00:31		
	08-juin-07	01:09:12	08/06/2007 01:09:17	FM8	WTG AutoRestart after GridError		NAF	00:00:05		00:00:05			
	08-juin-07	10:12:48	08/06/2007 10:13:19	FM332	LV Griderror 660V Alarm		GE	00:00:31			00:00:31		
	08-juin-07	10:13:19	08/06/2007 10:13:58	FM8	WTG AutoRestart after GridError		NAF	00:00:39		00:00:39			
	08-juin-07	11:19:46	08/06/2007 11:20:52	FM1201	MI class A Fault		AF	00:01:06	00:01:06				
	09-juin-07	03:45:29	09/06/2007 03:46:00	FM332	LV Griderror 660V Alarm		GE	00:00:31			00:00:31		
	09-juin-07	03:46:00	09/06/2007 03:56:03	FM8	WTG AutoRestart after GridError		NAF	00:10:03		00:10:03			
	12-juin-07	04:04:50	12/06/2007 04:05:21	FM332	LV Griderror 660V Alarm		GE	00:00:31			00:00:31		
	12-juin-07	04:05:21	12/06/2007 04:05:26	FM8	WTG AutoRestart after GridError		NAF	00:00:05		00:00:05			
	14-juin-07	13:45:08	14/06/2007 13:46:34	FM411	Wind DirSlanting Stop		AF	00:01:26	00:01:26				
	16-juin-07	12:33:10	16/06/2007 12:34:11	FM411	Wind DirSlanting Stop		AF	00:01:01	00:01:01				
	19-juin-07	12:18:18	19/06/2007 12:18:39	FM411	Wind DirSlanting Stop		AF	00:00:21	00:00:21				
	19-juin-07	20:22:03	19/06/2007 20:22:28	FM411	Wind DirSlanting Stop		AF	00:00:25	00:00:25				
	19-juin-07	20:35:18	19/06/2007 20:37:56	FM411	Wind DirSlanting Stop		AF	00:02:38	00:02:38				
	21-juin-07	11:36:38	21/06/2007 11:37:09	FM411	Wind DirSlanting Stop		AF	00:00:31	00:00:31				
	21-juin-07	14:13:58	21/06/2007 14:14:17	FM411	Wind DirSlanting Stop		AF	00:00:19	00:00:19				
	22-juin-07	16:24:50	22/06/2007 16:25:26	FM411	Wind DirSlanting Stop		AF	00:00:36	00:00:36				
	25-juin-07	17:55:06	25/06/2007 18:50:00	FM419	Yaw HydBrk not closed		AF	00:54:54	00:54:54				
	26-juin-07	17:12:25	26/06/2007 17:12:59	FM411	Wind DirSlanting Stop		AF	00:00:34	00:00:34				
	27-juin-07	10:32:31	27/06/2007 10:32:47	FM411	Wind DirSlanting Stop		AF	00:00:16	00:00:16				
								1,34					
								01:06:01	00:11:02	00:03:07	00:00:00	Im Total 01:06:01	NAF Total 00:14:09
								1,09	0,18	0,05	0,00	1,10	0,24
3 WEA 8385	06-juin-07	02:12:35	06/06/2007 02:45:06	FM1175	Pitch3 Batt.contactor Error		AF	00:32:31	00:32:31				
	06-juin-07	13:11:53	06/06/07 13:12:10	FM411	Wind DirSlanting Stop		AF	00:00:17	00:00:17				
	06-juin-07	13:38:01	06/06/07 13:38:16	FM411	Wind DirSlanting Stop		AF	00:00:15	00:00:15				
	06-juin-07	13:58:47	06/06/07 13:59:03	FM411	Wind DirSlanting Stop		AF	00:00:16	00:00:16				
	07-juin-07	20:43:55	07/06/07 20:44:27	FM332	LV Griderror 660V Alarm		GE	00:00:32			00:00:32		
	07-juin-07	20:44:27	07/06/07 20:52:11	FM8	WTG AutoRestart after GridError		NAF	00:07:44		00:07:44			
	07-juin-07	20:52:11	08/06/07 01:17:34	FM1175	Pitch3 Batt.contactor Error		AF	04:25:23	04:25:23				
	08-juin-07	01:17:34	08/06/07 01:17:47	FM6	WTG Manual Stop		AF	00:00:13	00:00:13				
	08-juin-07	10:12:48	08/06/07 10:13:19	FM332	LV Griderror 660V Alarm		GE	00:00:31			00:00:31		
	08-juin-07	10:13:19	08/06/07 10:13:58	FM8	WTG AutoRestart after GridError		NAF	00:00:39		00:00:39			
	08-juin-07	11:18:13	08/06/07 11:19:18	FM1201	MI class A Fault		AF	00:01:05	00:01:05				
	08-juin-07	11:19:18	08/06/07 11:24:45	FM1175	Pitch3 Batt.contactor Error		AF	00:05:27	00:05:27				
	09-juin-07	03:45:29	09/06/07 03:46:00	FM332	LV Griderror 660V Alarm		GE	00:00:31			00:00:31		
	09-juin-07	03:46:00	09/06/07 03:53:04	FM8	WTG AutoRestart after GridError		NAF	00:07:04		00:07:04			
	09-juin-07	03:53:04	09/06/07 03:56:15	FM161	Gear OilPmp Stage1 FuseTrip		AF	00:03:11	00:03:11				
	09-juin-07	04:01:19	09/06/07 04:19:06	FM1175	Pitch3 Batt.contactor Error		AF	00:17:47	00:17:47				
	14-juin-07	13:46:25	14/06/07 13:47:40	FM411	Wind DirSlanting Stop		AF	00:01:15	00:01:15				
	14-juin-07	14:55:25	14/06/07 15:24:44	FM165	Gear OilLevel 1 L Stopp		AF	00:29:19	00:29:19				
	17-juin-07	09:25:58	17/06/07 09:26:31	FM411	Wind DirSlanting Stop		AF	00:00:33	00:00:33				
	17-juin-07	09:27:35	17/06/07 09:53:24	FM261	RotBrk Brakepressure Fault		AF	00:25:49	00:25:49				
	17-juin-07	09:53:50	17/06/07 09:54:05	FM261	RotBrk Brakepressure Fault		AF	00:00:15	00:00:15				
	18-juin-07	12:52:41	18/06/07 12:53:09	FM411	Wind DirSlanting Stop		AF	00:00:28	00:00:28				
	19-juin-07	20:21:13	19/06/07 20:22:08	FM411	Wind DirSlanting Stop		AF	00:00:55	00:00:55				
	19-juin-07	20:35:35	19/06/07 20:38:05	FM411	Wind DirSlanting Stop		AF	00:02:30	00:02:30				
	19-juin-07	20:38:05	19/06/07 21:01:15	FM1003	Yaw CableRewind		NAF	00:23:10		00:23:10			
	19-juin-07	22:50:05	19/06/07 23:12:27	FM165	Gear OilLevel 1 L Stopp		AF	00:22:22	00:22:22				
	20-juin-07	10:15:51	20/06/07 10:16:21	FM411	Wind DirSlanting Stop		AF	00:00:30	00:00:30				
	21-juin-07	13:19:58	21/06/07 13:20:54	FM411	Wind DirSlanting Stop		AF	00:00:56	00:00:56				
	24-juin-07	20:09:26	24/06/07 20:19:09	FM165	Gear OilLevel 1 L Stopp		AF	00:09:43	00:09:43				
	24-juin-07	20:19:30	24/06/07 20:19:41	FM261	RotBrk Brakepressure Fault		AF	00:00:11	00:00:11				
	26-juin-07	17:17:25	27/06/07 06:20:48	FM165	Gear OilLevel 1 L Stopp		AF	13:03:23	13:03:23				
	27-juin-07	06:20:48	27/06/07 06:20:58	FM6	WTG Manual Stop		AF	00:00:10	00:00:10				
	27-juin-07	06:21:20	27/06/07 06:21:35	FM261	RotBrk Brakepressure Fault		AF	00:00:15	00:00:15				
	27-juin-07	06:21:35	27/06/07 06:21:42	FM165	Gear OilLevel 1 L Stopp		AF	00:00:07	00:00:07				
	29-juin-07	04:13:52	29/06/07 06:14:35	FM1175	Pitch3 Batt.contactor Error		AF	02:00:43	02:00:43				

AVAILABILITY

--

ACTIVE POWER

--

POWER CURVE

--

PREVENT MAINTENANCE

--

CORRECTIVE MAINTENANCE

--

UPGRADING REGISTER

--

MISCELLEANOUS:

--