

	N° Page
Resume of the Wind Farm	1
Bilan of the availability	2
Statistics of the Active power production	3
Power Curve	4
Status List	5
Comments	6

Report established by
The Turbine Management
Nordex France SAS

Customer : Endesa France
Name : Burlot
First Name : Franck
Address : 2, rue Jacques Daguerre
Code postal: F-92565
City : Reuil Malmaison Cedex
Phone : 01 47 52 40 01
Fax : 01 47 52 39 29
Email : franck.burlot@snet-electricite.fr

Operating company : NORDEX FRANCE SAS
Name : Service Maintenance
First Name :
Address : 1, rue de la procession
Code postal: F-93217
City : La plaine St Denis
Phone : 01 49 46 66 93
Fax : 01 55 93 43 40
Email : massoda@nordex-online.com



Wind Farm :	Lehaucourt	
Operating Company :	Nordex France	
Starting date for the availability :	01/04/2007	
Type of Turbine :	N90 R80 LS	
Number of the turbine :	4	
Power of the turbine :	2500	Kw
Power of the Wind Farm :	10000	Kw

Monthly report for the October 2007**Data Keys from the NC2:**

Availability of the Windfarm for the October 2007	94,90 %	
Availability of the Windfarm since the 01/04/07	92,60 %	
Active power production of the Windfarm to the 31/10/07	9 388 256	Kwh
Average production by turbines to the 31/10/07	2 347 064	Kwh

Stop Times Tstop AF October 2007	151:44:28	h
Stop Times Tstop NAF October 2007	197:53:48	h
Total Stop Time :	349:38:16	h

Comments:**Nordex France SAS**

Wind Farm

Customer :


Endesa France

Lehaucourt

Availability by Turbines - Monthly 2007/2008



	Apr 2007	May 2007	June 2007	July 2007	Aug 2007	Sept 2007	Oct 2007	Nov 2007	Dec 2007	Jan 2008	Feb 2008	Mar 2008
1 WEA 8383	60,32%	97,38%	99,99%	97,33%	99,70%	99,67%	94,98%					
2 WEA 8384	47,36%	93,79%	99,85%	99,95%	99,75%	99,95%	96,66%					
3 WEA 8385	80,71%	94,60%	96,93%	94,06%	95,08%	97,22%	90,87%					
4 WEA 8386	89,62%	90,45%	93,60%	96,59%	99,67%	87,66%	97,10%					
Farm	69,50%	94,05%	97,59%	96,98%	98,55%	96,12%	94,90%					




Wind Farm
Lehaucourt

Cust : **Endesa France**
Period : **Year of Expl. 2007/2008 - Farm Availability**



Annual availability
Farm 2007/2008

Apr 2007	May 2007	June 2007	July 2007	Aug 2007	Sept 2007	Oct 2007	Nov 2007	Dec 2007	Jan 2008	Feb 2008	Mar 2008	
69,50%	94,05%	97,59%	96,98%	98,55%	96,12%	94,90%						92,60%



Wind Farm
Lehaucourt

Customer
Period :

Endesa France
Year of Exploitation 2007/2008

Annual Statistics - Availabilities



April 2007					
WTG	Stop Times (AF) I _m	Stop Times (NAF)	Operating hours numbers M _m	Availability by turbines (Awtg)	Availability of the Farm by month
1 WEA 8383	285,67	35,26	720,00	60,32%	
2 WEA 8384	379,04	34,51	720,00	47,36%	
3 WEA 8385	138,90	43,47	720,00	80,71%	
4 WEA 8386	74,71	42,53	720,00	89,62%	69,50%
May 2007					
1 WEA 8383	19,52	76,94	744,00	97,38%	
2 WEA 8384	46,17	77,53	744,00	93,79%	
3 WEA 8385	40,19	78,38	744,00	94,60%	
4 WEA 8386	71,08	77,48	744,00	90,45%	94,05%
June 2007					
1 WEA 8383	0,10	0,42	720,00	99,99%	
2 WEA 8384	1,10	0,24	720,00	99,85%	
3 WEA 8385	22,10	0,67	720,00	96,93%	
4 WEA 8386	46,10	0,09	720,00	93,60%	97,59%
July 2007					
1 WEA 8383	19,86	34,89	744,00	97,33%	
2 WEA 8384	0,37	34,82	744,00	99,95%	
3 WEA 8385	44,18	34,83	744,00	94,06%	
4 WEA 8386	25,39	4,22	744,00	96,59%	96,98%
August 2007					
1 WEA 8383	2,20	1,34	744,00	99,70%	
2 WEA 8384	1,85	1,04	744,00	99,75%	
3 WEA 8385	36,58	1,08	744,00	95,08%	
4 WEA 8386	2,44	0,00	744,00	99,67%	98,55%

September 2007

1 WEA 8383	2,37	16,68	720,00	99,67%	
2 WEA 8384	0,34	16,48	720,00	99,95%	
3 WEA 8385	20,04	16,50	720,00	97,22%	
4 WEA 8386	88,87	16,32	720,00	87,66%	96,12%

October 2007

1 WEA 8383	37,35	50,02	744,00	94,98%	
2 WEA 8384	24,84	49,48	744,00	96,66%	
3 WEA 8385	67,95	49,65	744,00	90,87%	
4 WEA 8386	21,59	48,75	744,00	97,10%	94,90%

Wind Farm
Lehaucourt

Customer :
Period :

Endesa France
Year of Exploitation 2007/2008




Annual Statistics - Availabilities

2007/2008

Annual Estimates

					Wind Farm
WTG	I _m	NAF	M _m	Rate : until the 31.10.2007	92,59679%
1 WEA 8383	367,07	215,54	5136,00	92,85%	
2 WEA 8384	453,72	214,09	5136,00	91,17%	
3 WEA 8385	369,95	224,59	5136,00	92,80%	
4 WEA 8386	330,18	189,40	5136,00	93,57%	
Sum :	1520,91	843,62	20544,00		




Wind Farm: Lehaucourt

Customer : Endesa France

Year of Exploitation 2007/2008 - Production (kWh) WTG / Months



	Apr 07	May 07	June 07	July 07	Aug 07	Sept 07	Oct 07	Nov 07	Dec 07	Jan 08	Feb 08	Mar 08	Year 2007/2008
1 WEA 8383	186 033	536 318	358 519	432 984	380 038	339 665	221 456						2 455 013
2 WEA 8384	132 797	536 533	350 109	461 782	412 218	363 810	251 863						2 509 112
3 WEA 8385	294 771	482 323	301 776	392 032	341 628	304 798	215 026						2 332 354
4 WEA 8386	232 308	400 945	291 380	371 554	325 505	271 397	198 688						2 091 777
Farm	845 909	1 956 119	1 301 784	1 658 352	1 459 389	1 279 670	887 033						9 388 256



**Wind Farm
Lehaucourt**

Customer :

Endesa France

Month :

October 07

Statistics of the production

	Amount [kWh]	Estimate of the amount H.T. [€]	Estimate of the amount (with TVA)
Total Monthly Production of the Farm from the SCADA :	887 033	72 736,71 €	86 993,10 €
Cumulated Production of the Farm from the SCADA since the 01.04.2007 :	9 388 256	769 836,99 €	920 725,04 €
Total Production WindFarm from the SCADA cummulated since the erection :	1 191 000 10 032 873	23 820,00 € 822 695,59 €	28 488,72 € 983 943,92 €
<u>Invoice of the EDF</u> Gross Power supply	857 870	70 345,34 €	84 133,03 €
Data deviations WTGs - EDF [%]	3,399	Gross Power supply kWh from the EDF cummulated since the 01.04.2007	9 207 783,00 kWh

WTG	Monthly Production SCADA [kWh]	Production SCADA [kWh] since the 01.04.2007	Production SCADA [kWh] since the Erection
1 WEA 8383	221 456	2 455 013	2 767 893
2 WEA 8384	251 863	2 509 112	3 014 961
3 WEA 8385	215 026	2 332 354	2 826 966
4 WEA 8386	198 688	2 091 777	2 614 053
sum :	887 033	9 388 256	11 223 873

Comments :

Average Production per WTG
(From SCADA)

221 758

Wind Farm :
Lehaucourt

Customer :

Endesa France

Period :

October 2007



Status List

Status List		beginning :		end :		h / min / s		Prevent Maintenance						
WTG	date	hours	hours	code	error	actions/comments	AF/NAF	duration	Tstop/AF/ l _m	T stop/NAF T _{fm}	T stop/NAF grid	T Im		
1 WEA 8383	06-oct-07	20:04:03	07/10/2007 10:08:48	FM50	SafetyChain Activated		AF	14:04:45	14:04:45					
	07-oct-07	10:08:48	07/10/2007 10:11:21	FM4	WTG Maintenance		AF	00:02:33	00:02:33					
	07-oct-07	10:11:22	07/10/2007 10:22:59	FM6	WTG Manual Stop	MI Class B	AF	00:11:37	00:11:37					
	07-oct-07	10:38:02	07/10/2007 13:00:00	FM0 (FM4)	sysokoff-> WTG Maintenance		AF	02:21:58	02:21:58					
	09-oct-07	05:39:13	09/10/2007 08:39:57	FM332	LV Griderror 660V Alarm		NAF	03:00:44		03:00:44				
	09-oct-07	08:39:57	09/10/2007 12:20:00	FM11	PLC Reboot active		AF	03:40:03	03:40:03					
	12-oct-07	13:42:50	12/10/2007 13:42:50	FM1201	MI class A Fault		AF	00:00:00	00:00:00					
	12-oct-07	13:42:50	12/10/2007 15:50:12	FM332	LV Griderror 660V Alarm		NAF	02:07:22		02:07:22				
	12-oct-07	15:50:12	12/10/2007 17:20:00	FM11	PLC Reboot active		AF	01:29:48	01:29:48					
	17-oct-07	16:54:39	17/10/2007 17:17:42	FM1003	Yaw CableRewind		NAF	00:23:03		00:23:03				
	23-oct-07	06:50:53	23/10/2007 16:02:50	FM6	WTG Manual Stop		AF	09:11:57	09:11:57					
	24-oct-07	06:40:30	24/10/2007 11:22:10	FM6	WTG Manual Stop		AF	04:41:40	04:41:40					
	25-oct-07	07:12:06	25/10/2007 08:08:14	FM55	GenRot RpmMonitor Stop		AF	00:56:08	00:56:08					
	25-oct-07	08:08:14	25/10/2007 08:08:28	FM6	WTG Manual Stop		AF	00:00:14	00:00:14					
	27-oct-07	06:34:13	27/10/2007 07:14:46	FM6	WTG Manual Stop		AF	00:40:33	00:40:33					
	27-oct-07	13:00:09	29/10/2007 09:30:00	FM332	LV Griderror 660V Alarm		NAF	44:29:51		44:29:51				
								87.37						
								37:21:16	50:01:00	00:00:00	00:00:00	Im Total 37:21:16	NAF Total 50:01:00	
								23.28	50.02	0.00	0.00	37.35	50.02	
2 WEA 8384	05-oct-07	07:09:01	05/10/2007 07:32:03	FM1003	Yaw CableRewind		NAF	00:23:02		00:23:02				
	05-oct-07	10:09:55	05/10/2007 10:11:11	FM411	Wind DirSlanting Stop		AF	00:01:16	00:01:16					
	09-oct-07	05:39:12	09/10/2007 08:35:56	FM332	LV Griderror 660V Alarm		NAF	02:56:44		02:56:44				
	09-oct-07	08:35:56	09/10/2007 12:20:00	FM11	PLC Reboot active		AF	03:44:04	03:44:04					
	09-oct-07	21:31:17	09/10/2007 21:32:35	FM411	Wind DirSlanting Stop		AF	00:01:18	00:01:18					
	12-oct-07	13:42:49	12/10/2007 13:42:49	FM1201	MI class A Fault		AF	00:00:00	00:00:00					
	12-oct-07	13:42:49	12/10/2007 15:45:17	FM332	LV Griderror 660V Alarm		NAF	02:02:28		02:02:28				
	12-oct-07	15:45:17	12/10/2007 17:00:00	FM11	PLC Reboot active		AF	01:14:43	01:14:43					
	20-oct-07	11:15:38	20/10/2007 15:02:31	FM6	WTG Manual Stop		AF	03:46:53	03:46:53					
	22-oct-07	06:48:13	22/10/2007 16:20:46	FM6	WTG Manual Stop		AF	09:32:33	09:32:33					
	22-oct-07	16:47:07	22/10/2007 16:59:36	FM6	WTG Manual Stop		AF	00:12:29	00:12:29					
	25-oct-07	06:43:16	25/10/2007 12:15:02	FM6	WTG Manual Stop		AF	05:31:46	05:31:46					
	27-oct-07	07:23:22	27/10/2007 08:07:06	FM6	WTG Manual Stop		AF	00:43:44	00:43:44					
	27-oct-07	13:00:09	29/10/2007 09:06:27	FM332	LV Griderror 660V Alarm		NAF	44:06:18		44:06:18				
	29-oct-07	09:06:27	29/10/2007 09:08:19	FM11	PLC Reboot active		AF	00:01:52	00:01:52					
								74.32						
								Summen:	24:50:38	49:28:32	00:00:00	00:00:00	Im Total 24:50:38	NAF Total 49:28:32
								24.84	49.09	0.00	0.00	24.84	49.48	
	3 WEA 8385	05-oct-07	01:18:27	05/10/2007 02:13:30	FM1175	Pitch3 Batt.contactor Error		AF	00:55:03	00:55:03				
05-oct-07		02:13:43	05/10/2007 02:14:11	FM261	RotBrk Brakepressure Fault		AF	00:00:28	00:00:28					
05-oct-07		02:16:03	05/10/2007 08:50:14	FM1175	Pitch3 Batt.contactor Error		AF	06:34:11	06:34:11					
05-oct-07		08:50:14	05/10/2007 10:19:32	FM6	WTG Manual Stop		AF	01:29:18	01:29:18					
05-oct-07		10:20:01	05/10/2007 10:20:53	FM261	RotBrk Brakepressure Fault		AF	00:00:52	00:00:52					
05-oct-07		10:23:12	05/10/2007 10:23:27	FM1175	Pitch3 Batt.contactor Error		AF	00:00:15	00:00:15					
05-oct-07		10:25:32	05/10/2007 10:29:18	FM1175	Pitch3 Batt.contactor Error		AF	00:03:46	00:03:46					
05-oct-07		10:29:18	05/10/2007 10:29:40	FM11	PLC Reboot active		AF	00:00:22	00:00:22					
05-oct-07		10:34:09	05/10/2007 10:34:20	FM261	RotBrk Brakepressure Fault		AF	00:00:11	00:00:11					
06-oct-07		12:54:27	06/10/2007 12:55:45	FM411	Wind DirSlanting Stop		AF	00:01:18	00:01:18					
06-oct-07		12:56:10	06/10/2007 13:12:36	FM261	RotBrk Brakepressure Fault		AF	00:16:26	00:16:26					
06-oct-07		13:12:55	06/10/2007 13:13:05	FM261	RotBrk Brakepressure Fault		AF	00:00:10	00:00:10					
09-oct-07		05:39:13	09/10/2007 08:26:44	FM332	LV Griderror 660V Alarm		NAF	02:47:31		02:47:31				
09-oct-07		08:26:44	09/10/2007 08:27:24	FM11	PLC Reboot active		AF	00:00:40	00:00:40					
12-oct-07		13:42:49	12/10/2007 13:42:49	FM1201	MI class A Fault		AF	00:00:00	00:00:00					
12-oct-07		13:42:49	12/10/2007 15:38:23	FM332	LV Griderror 660V Alarm		NAF	01:55:34		01:55:34				
12-oct-07		15:38:23	12/10/2007 15:39:03	FM11	PLC Reboot active		AF	00:00:40	00:00:40					
15-oct-07		13:39:29	15/10/2007 14:02:39	FM1003	Yaw CableRewind		NAF	00:23:10		00:23:10				
15-oct-07		14:03:23	15/10/2007 14:48:37	FM261	RotBrk Brakepressure Fault		AF	00:45:14	00:45:14					
15-oct-07		14:48:52	15/10/2007 14:48:59	FM261	RotBrk Brakepressure Fault		AF	00:00:07	00:00:07					
19-oct-07		15:49:56	19/10/2007 16:36:33	FM1175	Pitch3 Batt.contactor Error		AF	00:46:37	00:46:37					
19-oct-07		16:36:50	19/10/2007 16:38:25	FM261	RotBrk Brakepressure Fault		AF	00:01:35	00:01:35					
19-oct-07		16:38:50	19/10/2007 16:39:23	FM261	RotBrk Brakepressure Fault		AF	00:00:33	00:00:33					
19-oct-07		16:39:23	19/10/2007 16:39:45	FM6	WTG Manual Stop	Reset	AF	00:00:22	00:00:22					
19-oct-07		16:40:14	19/10/2007 20:46:31	FM261	RotBrk Brakepressure Fault		AF	04:06:17	04:06:17					
19-oct-07		20:46:31	21/10/2007 14:05:31	FM6	WTG Manual Stop	Maintenance type 3	AF	41:19:00	41:19:00					
21-oct-07		14:05:59	21/10/2007 14:06:05	FM261	RotBrk Brakepressure Fault		AF	00:00:06	00:00:06					
24-oct-07		12:06:59	24/10/2007 15:35:49	FM6	WTG Manual Stop		AF	03:28:50	03:28:50					
24-oct-07		15:36:14	24/10/2007 15:37:21	FM261	RotBrk Brakepressure Fault		AF	00:01:07	00:01:07					
24-oct-07		15:39:50	24/10/2007 15:45:56	FM261	RotBrk Brakepressure Fault		AF	00:06:06	00:06:06					
24-oct-07		15:47:46	24/10/2007 15:48:11	FM1175	Pitch3 Batt.contactor Error		AF	00:00:25	00:00:25					
26-oct-07		06:52:06	26/10/2007 14:39:03	FM6	WTG Manual Stop		AF	07:46:57	07:46:57					
26-oct-07		14:44:20	26/10/2007 14:44:51	FM705	RotBrk Temp CableCut		AF	00:00:31	00:00:31					
26-oct-07		14:45:03	26/10/2007 14:45:18	FM705	RotBrk Temp CableCut		AF	00:00:15	00:00:15					
26-oct-07		16:02:30	26/10/2007 16:03:10	FM6	WTG Manual Stop		AF	00:00:40	00:00:40					
26-oct-07		23:54:26	27/10/2007 00:01:14	FM1175	Pitch3 Batt.contactor Error		AF	00:06:48	00:06:48					
27-oct-07		10:02:03	27/10/2007 10:02:15	FM705	RotBrk Temp CableCut		AF	00:00:12	00:00:12					
27-oct-07		13:00:09	29/10/2007 09:33:09	FM332	LV Griderror 660V Alarm		NAF	44:33:00		44:33:00				
29-oct-07		09:33:09	29/10/2007 09:35:01	FM11	PLC Reboot active		AF	00:01:52	00:01:52					
								117.61						
								Summen:	67:57:14	49:39:15	00:00:00	00:00:00	Im Total 67:57:14	NAF Total 49:39:15

67,04 49,65 0,00 0,00 67,95 49,65

4 WEA 8386

05-oct-07	06:26:35	05/10/07 06:49:44	FM1003	Yaw CableRewind		NAF	00:23:09		00:23:09		
08-oct-07	10:59:44	08/10/07 12:00:41	FM6	WTG Manual Stop		AF	01:00:57	01:00:57			
08-oct-07	12:00:41	08/10/07 12:09:03	FM6	WTG Manual Stop		AF	00:08:22	00:08:22			
09-oct-07	05:39:13	09/10/07 08:18:16	FM332	LV Griderror 660V Alarm		NAF	02:39:03		02:39:03		
09-oct-07	08:18:16	09/10/07 08:18:56	FM11	PLC Reboot active		AF	00:00:40	00:00:40			
09-oct-07	21:31:29	09/10/07 21:32:44	FM411	Wind DirSlanting Stop		AF	00:01:15	00:01:15			
12-oct-07	13:42:49	12/10/07 15:35:13	FM332	LV Griderror 660V Alarm		NAF	01:52:24		01:52:24		
12-oct-07	15:35:13	12/10/07 15:35:53	FM11	PLC Reboot active		AF	00:00:40	00:00:40			
18-oct-07	09:08:08	18/10/07 11:40:13	FM6	WTG Manual Stop	Maintenance type 3	AF	02:32:05	02:32:05			
19-oct-07	06:49:45	19/10/07 17:04:45	FM6	WTG Manual Stop		AF	10:15:00	10:15:00			
19-oct-07	17:10:26	19/10/07 17:11:31	FM1201	MI class A Fault		AF	00:01:05	00:01:05			
20-oct-07	06:20:02	20/10/07 09:25:51	FM6	WTG Manual Stop		AF	03:05:49	03:05:49			
25-oct-07	12:11:41	25/10/07 16:06:08	FM6	WTG Manual Stop		AF	03:54:27	03:54:27			
27-oct-07	08:18:35	27/10/07 08:52:55	FM6	WTG Manual Stop		AF	00:34:20	00:34:20			
27-oct-07	13:00:09	29/10/07 08:50:34	FM332	LV Griderror 660V Alarm		NAF	43:50:25		43:50:25		
29-oct-07	08:50:34	29/10/07 08:51:14	FM11	PLC Reboot active		AF	00:00:40	00:00:40			

70,34
 Summen: 21:35:20 48:45:01 00:00:00 00:00:00 Im Total 21:35:20 NAF Total 48:45:01
 21,59 48,36 0,00 0,00 21,59 48,75

AVAILABILITY

ACTIVE POWER

POWER CURVE

PREVENT MAINTENANCE

CORRECTIVE MAINTENANCE

UPGRADING REGISTER

MISCELLEANOUS: