

SNET
Lacq (2x109FB)
Lacq
CCA11291ENG Rev:2

by: Yann Raymond
24-Apr-2008

109FB Single Shaft
Conditions Ambiantes: 1.001 bar,a, 13.1 °C, 79.20 % RH
Gas Naturel, DLN **CC en charge de base ; performances pour une tranche 109FB**
Turbine à Gaz: PG9371 **Conditions ambiantes moyennes**
Turbine à Vapeur: 1 x 1,219.3 mm LSB **Emissions 30 mg NOx**

1. Performance de la Centrale

1.1 Puissance (kW)

Gross Equipment Power *	425840
Equipment Auxiliary Power	750
Net Equipment Power	425090
Plant Auxiliary Power	9386
Net Plant Power	415704
* Gross Power At Generator Terminals Minus Excitation Power	

1.2 Combustible

Type de Combustible -Gaz Naturel		
Specification - GEI 41040G Spécifications supplémentaires		
Système de Combustion - DLN		
Pouvoir Calorifique Inférieur (kJ/kg)	PCI	48,018.
Consommation (10^6 kJ/hr)	PCI	2,618.5

1.3 Consommation Spécifique

1.3.1 Net Equipment Heat Consumption (kJ/kWh)	PCI	6,160.
1.3.2 Net Equipment Efficiency (%)	PCI	58.44
1.3.3 Net Plant Heat Rate (kJ/kWh)	PCI	6,299.
1.3.4 Net Plant Efficiency (%)	PCI	57.15

1.4 Conditions d'Opération

Temperature Ambiante de l'Air (°C)	Sèche	13.1
	Humide	11.1
Humidité Relative Ambiante de l'Air (%)		79.20
Pression Ambiante de l'Air (bar,a)		1.001
Altitude du Site (m above MSL)		0
Température à l'Entrée du Compresseur (°C)	Sèche	13.1
Humidité Relative à l'Entrée du Compresseur (%)		78.36
Pression à l'Echappement de la Turbine à Vapeur (mm Hga (@15°C)A)		38.05

1.5 Equipment Auxiliary Power (kW)

1.5.1 Gas Turbine (1 GT), Steam Turbine (1 ST), Generator (1 GEN)

Lube Oil Pump
Hydraulic Oil Pump
Compartment Vent Fans
Seal Oil Pump
Lube Oil Tank Exhauster
Exhaust Frame Blower
Heating and Cooling Pump
Vapor Extractor
Conditioning Pump
Steam Gland Exhauster
Controls
GT Controls & Instrumentation

Turbine Subtotal 697.5

1.5.2 Heat Recovery Steam Generator (1 HRSG)

Controls & Instrumentation 20
Low Pressure Economizer Recirculation Pump 30


Total Equipment Auxiliary Power 750

1.6 Plant Auxiliary Power (kW)

Condensate pumps 429
Combined HP/IP Boiler Feedwater pumps 2249
Circulating Cooling Water Pumps 2006
Cooling Tower Fans 1244
Main Transformer Losses 1480
Vacuum Pumps 43
Water Pumps 73
Closed Circuit Cooling Water Pumps 183
Air Compressors 96
HVAC & Miscellaneous BOP **Note 1** 513
Chemical Plants 5
Demi Water Treatment Plant **Note 2** 0
Waste Water Treatment System 126
Auxiliary Transformer Losses 189
Miscellaneous electrical losses and lighting **Note 3** 749

Total Plant Auxiliary Power 9386

- Note 1 :** Minimum consumption of HVAC system due to partial switch-off (e.g electrical and turbine building) during performance test as per INTEC criteria
Note 2 : Considering full demin water tanks during performance test
Note 3 : Minimum consumption of lighting due to partial switch-off during performance test as per INTEC criteria



SNET
Lacq (2x109FB)
Lacq
CCA11292ENG Rev:1

by: Yann Raymond
24-Apr-2008

109FB Single Shaft

Conditions Ambiantes: 1.001 bar,a, 13.1 °C, 79.20 % RH

Gas Naturel, DLN

CC à 53% charge ; performances pour une tranche 109FB

Turbine à Gaz: PG9371

Conditions ambiantes moyennes

Turbine à Vapeur: 1 x 1,219.3 mm LSB

Emissions 30 mg NOx

1. Performance de la Centrale

1.1 Puissance (kW)

Gross Equipment Power *	227880
Equipment Auxiliary Power	750
Net Equipment Power	227130
Plant Auxiliary Power	8697
Net Plant Power	218433
* Gross Power At Generator Terminals Minus Excitation Power	

1.2 Combustible

Type de Combustible -Gaz Naturel

Specification - GEI 41040G Spécifications supplémentaires

Système de Combustion - DLN

Pouvoir Calorifique Inférieur (kJ/kg)	PCI	48,018.
---------------------------------------	-----	---------

Consommation (10 ⁶ kJ/hr)	PCI	1,565.5
--------------------------------------	-----	---------

1.3 Consommation Spécifique

1.3.1 Net Equipment Heat Consumption (kJ/kWh)	PCI	6,893.
---	-----	--------

1.3.2 Net Equipment Efficiency (%)	PCI	52.23
------------------------------------	-----	-------

1.3.3 Net Plant Heat Rate (kJ/kWh)	PCI	7,167.
------------------------------------	-----	--------

1.3.4 Net Plant Efficiency (%)	PCI	50.23
--------------------------------	-----	-------

1.4 Conditions d'Opération

Temperature Ambiante de l'Air (°C)	Sèche	13.1
	Humide	11.1
Humidité Relative Ambiante de l'Air (%)		79.20
Pression Ambiante de l'Air (bar,a)		1.001
Altitude du Site (m above MSL)		0
Température à l'Entrée du Compresseur (°C)	Sèche	24.9
Humidité Relative à l'Entrée du Compresseur (%)		37.50
Pression à l'Echappement de la Turbine à Vapeur (mm Hga (@15°C)A)		27.32

1.5 Equipment Auxiliary Power (kW)

1.5.1 Gas Turbine (1 GT), Steam Turbine (1 ST), Generator (1 GEN)

Lube Oil Pump
Hydraulic Oil Pump
Compartment Vent Fans
Seal Oil Pump
Lube Oil Tank Exhauster
Exhaust Frame Blower
Heating and Cooling Pump
Vapor Extractor
Conditioning Pump
Steam Gland Exhauster
Controls
GT Controls & Instrumentation

Turbine Subtotal 697.5

1.5.2 Heat Recovery Steam Generator (1 HRSG)

Controls & Instrumentation 20
Low Pressure Economizer Recirculation Pump 27

Total Equipment Auxiliary Power 750

1.6 Plant Auxiliary Power (kW)

Condensate pumps 364
Combined HP/IP Boiler Feedwater pumps 2248
Circulating Cooling Water Pumps 2007
Cooling Tower Fans 1244
Main Transformer Losses 856
Vacuum Pumps 43
Water Pumps 73
Closed Circuit Cooling Water Pumps 183
Air Compressors 96
HVAC & Miscellaneous BOP **Note 1** 513
Chemical Plants 5
Demi Water Treatment Plant **Note 2** 0
Waste Water Treatment System 126
Auxiliary Transformer Losses 189
Miscellaneous electrical losses and lighting **Note 3** 749

Total Plant Auxiliary Power 8697

- Note 1 :** Minimum consumption of HVAC system due to partial switch-off (e.g electrical and turbine building) during performance test as per INTEC criteria
Note 2 : Considering full demin water tanks during performance test
Note 3 : Minimum consumption of lighting due to partial switch-off during performance test as per INTEC criteria

